NORTHERN LAKE SERVICE, INC.
Analytical Laboratory and Environmental Services
400 North Lake Avenue - Crandon, WI 54520
Ph: (715)-478-2777 Fax: (715)-478-3060

ANALYTICAL REPORT

WDNR Laboratory ID No. 721026460
WDATCP Laboratory Certification No. 105-330
EPA Laboratory ID No. WI00034

NLS Project: 175740
NLS Customer: 02130

Client: Bad River Water & Sewer Dept
Attn: Pat Hunt
Firehall
PO Box 39
Odanah, WI 54861 0039

Fax: 715 682 7775 Phone: 715 682 7156
PO # 152218

Project: Bactis

Birch Hill NLS ID: 655560
COC: 141227:1 Matrix: DW
Collected: 03/22/12 09:10 Received: 03/23/12
Notes: Bottle received with Sodium Thiosulfate preservative.

Parameter	Result	Units	Dilution	LOD	LOQ/MCL	Analyzed	Method	Lab
Total Coliform Bacteria	Negative					03/23/12	SM 9223B	105330
E. coli	Negative					03/23/12	SM 9223B	105330
	Colilert Used							

Franks Field NLS ID: 655561
COC: 141227:2 Matrix: DW
Collected: 03/22/12 09:30 Received: 03/23/12
Notes: Bottle received with Sodium Thiosulfate preservative.

Parameter	Result	Units	Dilution	LOD	LOQ/MCL	Analyzed	Method	Lab
Total Coliform Bacteria	Negative					03/23/12	SM 9223B	105330
E. coli	Negative					03/23/12	SM 9223B	105330
	Colilert Used							

New Odanah 1 NLS ID: 655562
COC: 141227:3 Matrix: DW
Collected: 03/22/12 10:00 Received: 03/23/12
Notes: Bottle received with Sodium Thiosulfate preservative.

Parameter	Result	Units	Dilution	LOD	LOQ/MCL	Analyzed	Method	Lab
Total Coliform Bacteria	Negative					03/23/12	SM 9223B	105330
E. coli	Negative					03/23/12	SM 9223B	105330
	Colilert Used							

New Odanah 2 NLS ID: 655563
COC: 141227:4 Matrix: DW
Collected: 03/22/12 10:25 Received: 03/23/12
Notes: Bottle received with Sodium Thiosulfate preservative.

Parameter	Result	Units	Dilution	LOD	LOQ/MCL	Analyzed	Method	Lab
Total Coliform Bacteria	Negative					03/23/12	SM 9223B	105330
E. coli	Negative					03/23/12	SM 9223B	105330
	Colilert Used							

Diaperville NLS ID: 655564
COC: 141227:5 Matrix: DW
Collected: 03/22/12 10:40 Received: 03/23/12

Parameter	Result	Units	Dilution	LOD	LOQ/MCL	Analyzed	Method	Lab
Total Coliform Bacteria	Negative					03/23/12	SM 9223B	105330
E. coli	Negative					03/23/12	SM 9223B	105330
	Colilert Used							